

# CYLINDER HYDRO TEST

Certificate no: DSC-2026-000686

Service date: 20.05.2026

Valid until: 20.05.2028

Result: **Approved**

## Equipment details

Customer: Bergen Brannvesen AS  
Producer: Interspiro  
Serial no: RA6513  
Service interval: 24 months

Location: Bergen Brannvesen  
Model: Cylinder  
Build year: 2015

## Data

Cylinder type: Steel                      Color: white                      Cylinder volume: 4.0  
Oxygen cleaned: No                      Working pressure (bar): 300                      Test pressure (bar): 450                      Application type: Diving  
Test facility number: D79                      Weight (kg): 5.60                      Thread type: M18                      Hydro tested: 05/2026

## Exterior

Heat damage	Pass	Weight	Pass
Repainted	No	Line corrosion	Pass
Hammer test	Pass	Exterior condition	Pass
Odor	Pass	Minimum wall thickness	Pass
Dent or bulge	Pass	Exterior approved	Pass

## Interior

Interpreted (thread verification)	Pass	Amount of loose material	Pass
Threads approved	Pass	Pitting corrosion depth	Pass
Crack formation	Pass	Interior approved	Pass
Sealing surface damaged	Pass		

## Pressure testing

Water temperature	Pass	PU (test pressure reached)	Pass
Water fill (in)	Pass	PU% (percentage of test pressure)	Pass
Water drain (out)	Pass	Pressure testing approved	Pass

## Valve

Overhauled	Yes	Filling connection thread	Pass
Valve/cylinder thread	Pass		



# CYLINDER HYDRO TEST

Certificate no: DSC-2026-000686

Service date: 20.05.2026

Valid until: 20.05.2028

Result: **Approved**

## General

Repairs on cylinder

No

Cylinder and valve approved

Pass

## Technician

Serviced by: Daniel Kristensen

Signature

